



UNIVERSITY OF MAINE SYSTEM

REQUEST FOR PROPOSALS #2024-084
Heavy Transport
RESPONSE ADDENDUM #1
June 7, 2024

CLARIFICATION

QUESTIONS

Q1: How much of the concrete foundation can cantilever off the sides of the SPMT while transporting?

A1: The structure has been evaluated for the overhang as depicted in attachment A. The structure can handle this loading. The design of the cribbing and raised platform necessitate the two SPMT's in the configuration shown as some of the supporting must be removed to allow transport.